


PROFIBUS DP / LWL

coupler 2. generation





Control and regulation components MODEX

PROFIBUS DP / LWL coupler. Type 07-7311-97WP



Definition

The PROFIBUS LWL - coupler reroutes the PROFIBUS from copper conductors to optical waveguides. The coupler is a passive bus participant and are suitable for hazardous areas of zone 1 and 21. In plants, the PROFIBUS LWL - coupler allows the bridging of great distance with PROFINET without noice interference.

- Ring-coupler, P-P-coupler, T-couple
- Automatic master/slave detection
- Automatic build rate detection
- Fiberview for fibre optic ring monitoring

The electronics for the signal conversion are accommodated in the flameproof MODEX enclosure. Transmitter and receiver for the LWL-coupler are intrinsically safe headed. The intrinsically safe control transmitter and receiver of the electronic system guarantee that the transmitter rate does not go beyond maximum value limits.

Configuration

The interface modules of the LWL coupler serve the active coupling of RS485 two-wire bus lines, particularly the Profibus-DP or Profibus-FMS with optical wave-guide transmission paths.

Typ

*7 P		
07-7311-97WP6500	Profibus LWL P-P - Coupler	FSMA
07-7311-97WP6510	Profibus LWL P-P - Coupler	ST
07-7311-97WP4500	Profibus LWL T- Coupler	FSMA
07-7311-97WP4510	Profibus LWL T- Coupler	ST
07-7311-97WP5500	Profibus LWL Ring - Coupler	FSMA
07-7311-97WP5510	Profibus LWL Ring - Coupler	ST

With applicable documents

- Declaration of EU conformity
- Test certificates

These documents must be retained!

Intended Use

The PROFIBUS LWL - coupler are designed to meet the industrial requirements in hazardous (potentially explosive) areas.

Industrial Requirements of Zone 1

The modules are approved as "Ex d flameproof enclosures" with connecting terminals in "Ex e increased safety ex e". Since the open connecting terminals are Ex e, the modules are given a partial certificate with the "U" marking.

Special note concerning the "U" marking

The modules must be installed in an enclosure that meets the requirements of a recognised type of protection in accordance EN/IEC 60079-0, min. protection type IP54. When installing in an enclosure with "increased safety 'e'", the clearance and creep age distances in Tables 1+2 in IEC/EN 60079-7 must be complied with.

Intrinsically safe installed components

If installed components with intrinsically safe circuits are produced as associated apparatus, they undergo their own type examination by a notifed body. These are marked with an "X" after the test number.

The "X" indicates that special conditions apply to this device in the test certificate. These conditions can be read in the test certification.

Use in local control stations

Local control stations may generally be opened for testing and adjustment work. Work may be carried out on intrinsically safe circuits if all non-intrinsically safe circuits have an internal cover which, when the enclosure is open, corresponds to at least the following protection class IP 30 when the enclosure is open.

Explosionsschutz

Marking ATEX	© Zone 1/21
Certification	see bartec.com
Marking IECEx	Zone 1/21
Certification	see bartec.com
Marking CSA	Class I Zone 1
Certification	see bartec.com

Further approvals and test certificates can be found at ${\color{red}\text{bartec.com}}$

EU Conformity

RoHS Directive	2011/65/EU
Standards in accordance with EMC Directive 2014/30/EU	EN/IEC 61000-6-2:2005 EN 61000-6-4:2007 + A1:2011 IEC 61000-6-4:2006 + A1:2010
Product labelling	0044
Product labelling installation	€0044

Technical Data	
Physical characteristics	
Construction	flameproof clip-on enclosure
Enclosure material	high-quality thermoplastics
Protection class (EN/IEC 60529) Terminals Electronic module Terminals with cover	IP20 (minimum) IP66 IP30
Electric connections	terminals 2.5 mm², fine-stranded
Attachment onto mounting rail (EN/IEC 60715)	TH 35 x 15 (7.5)
Operating	LED Green: Operation indicator (ON)
	BA: LED green flashing: Bus activity LED red: no communication
	FV1 and FV2: LED Red: No connection LED Red/green=yellow: Light output borderline LED Green: Connection OK LED green or yellow flashing: Data reception
	Declaration: FV = Fiberview BA = BUS activity
Terminal marking	inscription label
Terminal screws	M 2.5 x 0.45 mm
Terminal screw torque	0.4 Nm
Mounting position	any
Weight	approx. 600 g
Dimensions	94 x 91 x 75 mm


PROFIBUS



Toohnical Data

Technical Data				
Ambient conditions				
Ambient temperature	-25 °C to +60 °C at T4			
Storage/transport temperature	-40 °C to +70 °C			
Relative Luftfeuchtigkeit	5 % to 95	5 % non-co	ndensing	
Vibration (EN 60068-2-6)	2 g/7 mn	n, 5-200 Hz	z in all 3 axes	
Shock (EN 60068-2-27)	15 g, 11 ı	ms in allen	3 Achsen	
Electrical Data				
Galvanic isolation	Bus//power supply//optical waveguide			
Bus input/output	2-wire remote bus with screw terminals			
Optical waveguide input/output	FSMA LWL plug-in connectors ST LWL plug-in connectors			
Supply voltage	L+, L- DC 20 V to DC 30 V			
Bit distortion	60 ns (max.)			
Power consumption dissipation	max. 3.0W			
Signal delay	max. 4,5 µs/typ. 3.4 µs and 5 ns per meter fibre optic			
Current consumption	approx. 125 mA at DC 24 V			
Distance/Optical budget				
Fiber/glass	approx. 2		50/125 μm 62.5/125 μm	4 dB 8 dB
Terminating resistor	Terminating resistor			

Dimensions / mounting positions



Marking

Particularly important points in these instructions are marked with a symbol:



DANGER indicates a hazardous situation which, if not avoided, will result in death or serious injury.



WARNING indicates a hazardous situation which, if not avoided, could result in death or serious injury.



CAUTION indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.



NOTICE is used to address practices not related to personal injury.



NOTE Important instructions and information on effective, economical and environmentally compatible handling.

Transport and storage



NOTICE

Damages due to improper storage!

- Observe storage and transport temperatures.
- Condensation can arise on components in a cold environment.
- Use the original packaging for transport/storage.

Installation

NOTICE

Damage due to improper handling!

 Assembly, disassembly, installation and commissioning may only be performed by qualified personnel who are authorized and trained to assemble electrical components in hazardous areas



Plugs:

 The plugs are difficult to pull off! Due to the high fitting accuracy of plug and socket, a vacuum is created during removal, which requires higher removal forces. For this reason, the plugs must be pulled off carefully to avoid damaging the plugs and connectors.



DANGER

Improper use, incorrect assembly and operation can operation endanger the explosion protection and can lead to and can lead to serious personal injury or damage to property.

The following special conditions must be heeded!

- Do not install and commission components that have been stored in a cold environment. Take conden-sation into consideration!
- 2. The enclosure has been sealed in the factory. The enclosure must not be opened!
- 3. Before installation, check whether the components are in perfect condition.
- 4. No conversions are changes to the module may be made.
- 5. Only work on the module when it is voltage-free
- 6. Units must be mounted at a distance of 8 mm from the to the nearest unit.
- 7. All screws and terminals must be tightened using a torque wrench, taking account of the recommended connection torque for screws and terminals of 0.4 Nm to 0.7 Nm. Suitable measures must be taken to ensure this.
- 8. Ensure the unit is dead (be aware of consumers with stored energy)
- 9. Cover any live neighbouring components.
- 10. The PA connection part must be connected with low impedance to the equipotential bonding conductor of the hazardous area. Since the intrinsically safe circuits are galvanically connected to ground potential, equipotential bonding of the intrinsically safe circuits must be maintained throughout the service life of the system.
- 11. Decommission the device in the event of a fault.

Bus termination

As a basic rule, the BUS must be terminated at the beginning and at the end of the bus segment. If an LWL coupler is connected at the beginning or at the end of the segment, it is possible to terminate the BUS with the aid of an internally fitted bus termination.

The devices are terminated by two electrical jumpers from terminal 9 (A) to terminal 8 (Ax) and from terminal 7 (Bx) to terminal 6 (B) (see terminal connection).

Projection of optical circle

Calculation of the circle-time:

 t_{Ring} = max. ring circle time (n-1) *

 t_{Ring} -coupler + I * $t_{Fibre \, optic}$

n = number of LWL couplers in ring

t_{Ring-coupler} = running time module - running time at Ring coupler = 4.5 ms

I = Length of fibre at ring

t_{Eibre optic} = running time per metre Ring coupler = 5 ns

The following values obtain:

Data rate Kbit/s	Running time	Max. distance between 2 Ring coupler
1 500	0.30 ms	0.7 km
500	0.90 ms	2.2 km
187.5	2.40 ms	2.6 km
93.75	4.80 ms	2.6 km
45.45	9.90 ms	2.6 km
19.2	23.44 ms	2.6 km
9.6	46.88 ms	2.6 km

Installation

Installation and commissioning may only be carried out by qualified personnel who are authorized and trained to install electrical components in potentially explosive atmospheres.



DANGER

Exposed live parts. Danger to life due to electric shock!!

• Only work on the module when it is de-energised state.




CAUTION

Infrared light! Danger to eyesight!

- Do not look into the laser beam of the transmitter
- In the event of a malfunction, put the device out of operation!

Wiring diagram / terminal assignment



Terminal connection

Terminal	Name	Terminal	Name	
1	(+) DC 24 V Power supply		Fault relay contact 1	
2	(-) DC 24 V Power supply	12	Fault relay contact 2	
3	Warning relay contact 1	13	NC	
4	Warning relay contact 2	14	NC	
5	(Termination) B	15	PA	
6	(Termination) B	16	PA	
7	(Termination) Bx	17	NC	
8	(Termination) Ax	18	NC	
9	(Termination) A	19	NC	
10	(Termination) A	20	NC	

Work steps

- Check the correct wiring of the fiber optic coupler before commissioning.
- The terminal devices to be connected by means of optical fibers must be switched off and de-energized. Snap the fiber optic coupler onto the TS35 mounting rail and check that the device is held securely.
- Activate the necessary terminating resistors at the beginning and end of the bus.
- Lay the FO cable according to the data sheet. Otherwise, the cable may be damaged and/or the communication between the FO ring couplers may no longer be guaranteed. Observe the routing instructions from your FO manufacturer.

Commissioning

Check before commissioning:

- 1. Has the module been installed correctly?
- 2. Is the enclosure undamaged?
- 3. Has the connection been carried out correctly?
- 4. Have you checked that the wiring is correct?
- 5. Does the module function correctly?
- 6. PA properly connected to equipotential bonding conductor

Operation

After the final inspection has been carried out, the device can be put into operation.

DANGER

There is a danger to life if the device is not used as intended!



- Observe the special conditions for explosion protection.
- Operate only within the permitted temperature range.
- Connect PA properly to equipotential bonding conductor.
- In the event of bus failure (communication error), the outputs go into fail-safe mode (go to 0 and are switched off!).

Troubleshooting

Troubleshooting during connection Establishment

- 7. Are the FO systems supplied with voltage?
- 8. Is the correct connection between the FO coupler and the terminal device ensured and has the correct interface been selected?
- 9. Are all screw terminals correctly tightened?
- 10. Is one optical transmitter connected to the optical receiver of the opposite device at a time (cross connection)?
- 11. Are the bus terminating resistors activated and have they been correctly selected and connected?
- 12. Is the transmission distance not too long?
- 13. Is the transmission rate correct and was the data rate set according to "Project planning"?
- 14. Have the guidelines for the individual modules of the software been observed?
- 15. Has the FO cable been laid correctly?
- 16. Are FO systems of other manufacturers in the ring? Only use BARTEC systems!

Maintenance, Inspection, Repair

Only authorised and qualified personnel may do any work on the control and regulating component.

Maintenance

If operated correctly in accordance with the installation instructions and ambient conditions, it does not require maintenance.

Inspection

Under EN/IEC 60079-17 and EN/IEC 60079-19 the owner/managing operator of electric installations in hazardous areas is obliged to have these installations checked by a qualified electrician to ensure that they are in a proper condition.

Repair

The component cannot be repaired. Please contact BARTEC GmbH if you have any questions.

Disposal

The regulating and control components contain metallic and plastic parts and electronic parts.



NOTE

Our devices involve electrical equipment which is only intended for commercial use (so-called B2B equipment in accordance with the WEEE Directive).

The regulating and control components must be disposed of in accordance with national regulations.

Our customers may return any products procured from us to our company for disposal. The sender must bear the costs for shipping/packing.

Amendments to the Document

BARTEC GmbH reserves the right to change the contents of this document without notification. We assume no guarantee for the correctness of the information. In cases of doubt the German safety instructions apply because it is not possible to rule out errors during printing and translation. The "General Terms and Conditions of Business" of the BARTEC Group moreover apply in the event of legal disputes.

The current version of data sheets, operating instructions, certificates and EC declarations of conformity can be downloaded from bartec.com or directly requested from BARTEC GmbH.

Order numbers

FSMA	07-7311-97WP6500
ST	07-7311-97WP6510
FSMA	07-7311-97WP4500
ST	07-7311-97WP4510
FSMA	07-7311-97WP5500
ST	07-7311-97WP5510
	ST FSMA ST FSMA

Serviceadresse


BARTEC GmbH

Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

Phone: +49 7931 597-0 info@bartec.com



Coupling example



The following values apply:

Fiber	Core/ Cladding	Incoupling power *	Receiver overmodulation limit	Receiver undermodulaltion limit	Typical fiber damping	Typical distance	Optical budget
Glass	50/125 μm	-18.2 dBm	-10 dBm	-32 dBm	-3 dB/km	2000 m	6 dB
Glass	62.5/125 μm	-14.5 dBm	-10 dBm	-32 dBm	-3 dB/km	3000 m	9 dB

^{*} The measured values in the table correspond to the peak values. The pertinent average values amount to -3 dBm.

Konformitätserklärung **Declaration of Conformity** Déclaration de conformité Nº 01-7311-7C0030 C



Wir	We	Nous
	BARTEC GmbH Max-Eyth-Straße 16 97980 Bad Mergentheim Germany	
erklären in alleiniger Verantwortung, dass das Produkt Steuer- und Regel- Komponente	declare under our sole responsibility that the product Control Component	attestons sous notre seule responsabilité que le produit Composants de commande et de regulation

07-7311-***/***

auf das sich diese Erklärung bezieht den Anforderungen der folgenden Richtlinien (RL) entspricht

ATEX-Richtlinie 2014/34/EU EMV-Richtlinie 2014/30/EU RoHS-Richtlinie 2011/65/EU

und mit folgenden Normen oder normativen Dokumenten übereinstimmt

> EN 60079-0:2018 EN 60079-1:2014 EN 60079-7:2015

EN 60079-11:2012

to which this declaration relates is in accordance with the provision of the following directives (D)

ATEX-Directive 2014/34/EU EMC-Directive 2014/30/EU RoHS-Directive 2011/65/EU

and is in conformity with the following standards or other normative documents

se référant à cette attestation correspond aux dispositions des directives (D) suivantes

Directive ATEX 2014/34/UE Directive CEM 2014/30/UE Directive RoHS 2011/65/UE

et est conforme aux normes ou documents normatifs ci-dessous

EN 61000-6-2:2005

EN 61000-6-4:2007 + A1:2011 EN 60529:1991+A1:2000+

A2:2013

Verfahren der EU-Baumusterprüfung / Benannte Stelle

Procedure of EU-Type Examination / Notified Body

Procédure d'examen UE de type / Organisme Notifié

PTB 97 ATEX 1068 U

0102, PTB, Bundesallee 100, 38116 Braunschweig, DE

0044

Bad Mergentheim, 10.11.2021

Product Manager Automation

Head of Global R&D ESS

BARTEC

BARTEC GmbH Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

Phone: +49 7931 597-0 info@bartec.com

bartec.com