

PNA


Cable glands unarmoured cables



Mechanical characteristics

Body/cab	OT-58 brass (ON) - AISI-316L stainless steel (XX) marine grade copper free aluminium (on project request only)
Finishes	Full nickel plating treatment (brass material only)
Rubber rings	EPDM rubber 50-60 shore hardness (standard supply) Silicon rubber 60 shore hardness (on demand only)
O-ring	Silicon rubber – 60 shore hardness
Skid washer	Nylon 6.0





Installation

Hazardous areas - Zone 1 / 2 (Gases) - Zone 21 / 22 (Dusts)

Classification

Group II - Category 2G 2D/3G 3D

Reference standards Directive 2014/34/EU

Execution	 ⑤ II 2 G Ex db / Ex eb/ Ex ia/ IIC Gb II 2 D Ex tb IIIC Db ⑤ II 3 G Ex nR IIC Gc / II 3 D Ex tc IIIC Dc 			
Rules of compliance	EN/IEC 60079-0; EN/IEC 60079-1; EN/IEC 60079-7; EN/IEC 60079-11; EN/IEC 60079-31			
EU type-examination certificate	INERIS 09 ATEX 0028X INERIS 23 ATEX 3004X (Ex nR only)			
Protection degree	IP66 or IP66/68			
Ambient temperature	-40 °C ÷ +90 °C (Rubber rings EPDM-60) -60 °C ÷ +180 °C (Rubber rings SILICON)			
Other available	IECEx: IECEx INE 11.0017X			
certificates	INMETRO: CEPEL 12.2177X			
	RINA: ELE411722CS			
	Russian marine certificate (RMRS): 19.02521.280			
	· · · · · · · · · · · · · · · · · · ·			
	19.02521.280			
	19.02521.280 CCC 2023122313116542			
	19.02521.280 CCC 2023122313116542 CCOE PESO: P531870			

Applications

For unarmoured cables only

Single compression type suitable for indoor and outdoor use

Single compression – on cable (inner sealing)

On Request Accessories

Locknuts, Gaskets, PVC Shrouds, Earthing Tags, Sealing (See DL-NW-PTD-ET bulletin)























Cable gland selection table

Code (1)	Cino	Entry thread size						Inner sheath Dia.		Hexagon	Matarial	(2)
	Size	Metric	(2)	NPT	(2)	ISO 228	(2)	min (mm)	max (mm)	(mm) Material	- Material	(3)
		ISO-M16		2 /0" NDT		3/8"		4,0	7,0	24.0	Nickel pl. brass	40
PNA#	00	150-1/110	М	3/8" NPT	N	3/0		7,0	10,0	24,0	Stainless steel	XX
	00	100 1400		1/2" NPT	IN	1/2"	- G	4,0	7,0	32,0	Nickel pl. brass	ON
		ISO-M20		1/2 INF1		1/2		7,0	10,0	32,0	Stainless steel	XX
PNA# 01	01	ISO-M20	М	1/2" NPT	N	1/2"	G	5,5 8,0	8,0 10,5	32,0	Nickel pl. brass	10
		130-14120	IVI					10,5	13,0		Stainless steel	XX
PNA#	02	ISO-M25	М	3/4" NPT	N	3/4"	G	10,5 13,0	13,0 15,5	26.0	Nickel pl. brass	ON
								15,5	18,0	36,0	Stainless steel	XX
PNA#	03	ISO-M32	М	1" NPT	N	1"	G	15,0 18,0	18,0 21,0	45,0	Nickel pl. brass	ON
		130-14132					G	21,0	24,0		Stainless steel	XX
PNA#	04	ISO-M40		1 1/4" NPT	N	1 1 / / !!		21,0 24,0	24,0 27,0	F0.0	Nickel pl. brass	ON
		130-140	M			1 1/4"	G	27,0	30,0	53,0	Stainless steel	XX
PNA# 05				1 1/2" NPT		1 1/2"	G	24,0 27,0	27,0 30,0	61,0	Nickel pl. brass	ON
	05	ISO-M50	М		N			30,0	33,0		Stainless steel	XX
							_	33,0	36,0			
PNA#	06	ISO-M63	М	2" NPT	Ν	2"	G	39,0	42,0	71,0	Nickel pl. brass	
								42,0	- 45,0 45,0		Stainless steel	XX
PNA#	07	ISO-M75	М	2 1/2" NPT	N	2 1/2"	G	45,0	48,0	84,0	Nickel pl. brass	ON
								48,0 51,0	51,0 54,0		Stainless steel	XX
PNA#		ISO-M90	М	3" NPT	N	3"	G	52,0	56,0	101,0	Nickel pl. brass	ON
	08							56,0 59,0	59,0 62,0			
								62,0 65,0	65,0 68,0		Stainless steel	XX
								68,0	74,0		Nickel pl. brass	
PNA#	09	ISO-M100	М	4" NPT	N	4"	4" G	74,0 80,0	80,0 86,0	126,0	— Nicket pt. brass	
								86,0			Stainless steel	XX
	,		_									
P N	A #	0 1 M	0 N	→ PNA#01M	ON (no	n-barrier cabl	e gland r	nickel plated b	orass ISO-M20	THR.)		
P N	A #	0 3 N	х	→ PNA#03N	XX (nor	-barrior cable	alanda	tainlana ataal	1 /2"NIDT TUD `			


Cable gland ordering examples

Legend

(1) -	cable gland type/model	PNA# = non-barrier cable gland				
(2) -	threading	M = ISO METRIC pitch 1,5mm / N = NPT (ANSI/ASME B1.20.1) - G = ISO-228				
(3) -	cable gland material	ON - nickel plated brass / XX = AISI-316l stainless steel				



PNA dimensional



1	Body
2 - 3 - 4	Inner sealing ring for not armoured cable
5	Press ring
6	Gland nut
7	O-ring (only for metrical)

REMARK:

Due to the development of the national and international specifications and of the technology, the above technical characteristics showed on this bulletin can be considered as binding on our confirmation only.