

Note on instructions

When working in hazardous areas, the safety of personnel and equipment depends on compliance with the relevant safety regulations. The people in charge of installation and maintenance bear a special responsibility. It is essential that they have an exact knowledge of the applicable rules and regulations.

The instructions provide a summary of the most important safety measures and must be read by everyone working with the product so that they will be familiar with the correct handling of the product.

The instructions have to be kept for future reference and must be available throughout the expected life of the product.

Description

The ComEx^{flex} lamp module, type 07-3353-4***/****, indicates command modes by lighting up or going out. The lamp module is used everywhere in almost all hazardous areas where the functional status of the respective machine is to be visually displayed.

The ComEx^{flex} lamp module is designed for combining with a lamp module actuator and a junction box. The ComEx^{flex} lamp module is attached without tools to the lamp module actuator. The connection is established by means of terminals at the back of the ComEx^{flex} lamp module.

The lamp module actuator is inserted into a mounting hole in an Ex e enclosure, a control console or control panel. The easy installation of the actuator allows conformance to a high IP degree of protection.

When inserted into a control console or control panel, there is the option of mounting the junction box. The junction box is connected to the ComEx^{flex} lamp module by means of two screws.

Explosion protection

ATEX

Ex type of protection

Ex II 2 G Ex db eb IIC Gb

Ex I M2 Ex db eb I Mb

Certification
CML 17 ATEX 1106U

IECEx

Ex type of protection Ex db eb IIC Gb Ex db eb I Mb

Certification IECEx CML 17.0046U

Other approvals and certificates, see www.bartec-group.com

Ambient temperature ranges

-55 °C to +50 °C (-67 °F to +122 °F) or +60 °C (+140 °F), if $U_e = 12 \text{ V}$ to 24 V

Operating temperature ranges

-55 °C bis +85 °C (-67 °F bis +185 °F)

Approved for zones

1 and 2

Storage/transport temperature

-55 °C to +70 °C (-67 °F to +158 °F)

Technical data

Protection class

Determined by lamp module actuator and control station enclosure.
Terminals: IP 20

With junction box and lamp module actuator: up to IP 67

Weight

Approx. 110 g (0.24 lb)

Rated voltage

300 V

Power consumption

≤1 W

Rated voltage (Ue)

AC 12 V to 250 V Ta < +50 °C (+122 °F) DC 12 V to 60 V Ta < +50 °C (+122 °F) AC/DC 12 V to 24 V Ta < +60 °C/ (+140 °F)

Enclosure material

Thermoplastic

Connection

Terminals for 2.5 mm², fine-wire

Lamp

LED (red, green, yellow, white, blue)

Illumination

Very bright, visible angle up to 180°

Service life

Electrical > 105 running hours

Mounting

Locked, by bayonet lock

Shock resistance

DIN EN 60068-2-27, 30 g 18 ms

Dimensions

See page 3

ComExflex Lamp module

Type 07-3353-41**/****

BARTEC

Safety Instructions

The ComEx^{flex} lamp module and the corresponding lamp module actuator may be used only within the specified ambient and operating temperature range.

Utilization in areas other than those specified or the modification of the product by anyone other than the manufacturer is not permitted and will exempt BARTEC from liability for defects and any further liability.

Incorrect installation can cause malfunctioning and the loss of explosion protection.

Only service technicians who are authorized to work in potentially explosive atmospheres may do any of the assembly, disassembly, installation, commissioning, maintenance, and fault clearance work.

The generally applicable statutory rules and other binding directives relating to workplace safety, accident prevention and environmental protection must be observed.

When setting up or operating explosion-resistant electrical systems, the IEC/EN 60079-14 (NEC for USA/CEC for Canada) and all relevant installation and operating regulations must be observed.

The ComEx^{flex} lamp module may be used only if it is in a clean and undamaged condition. It is not permissible to modify the lamp module in any way.

Marking

Particularly important points in these instructions are marked with a symbol:

⚠ DANGER

DANGER indicates a hazardous situation which, if not avoided, will result in death or serious injury.

↑ WARNING

WARNING indicates a hazardous situation which, if not avoided, could result in death or serious injury.

⚠ CAUTION

CAUTION indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.

NOTICE

NOTICE is used to address practices not related to personal injury.



Important instructions and information on effective, economical and environmentally compatible handling.

Standards conformed to

EN 60079-0:2012 + A11: 2013

EN 60079-1:2014

EN 60079-7:2007

EN 60068-2-27:2009

EN 61000-6-2:2008

EN 61000-6-4:2007 +A1:2011

IEC 60079-0:2011

IEC 60079-1:2014

IEC 60079-7:2006

IEC 60068-2-27:2008

IEC 61000-6-2:2005

IEC 61000-6-4:2006 + A1:2010

Transport, Storage

NOTIC

ComEx^{flex} lamp module damage through incorrect transport or incorrect storage.

- Transport and storage is permissible in original packaging only.
- Store the ComEx^{flex} lamp module in a dry place.

Assembly, Installation

⚠ WARNING

Risk of serious injury due to incorrect proceedings.

- The IEC/EN 60079-14 and further national standards and locally applicable installation regulations have to be observed.
- Ensure that the voltage supply has been isolated or take suitable protective measures.
- Pay attention to the type of mounting required (for fitting into enclosure/attachment with junction box).

Assembly


⚠ WARNING

Risk of serious accidents due to damaged parts.

Before assembly, ensure the perfect condition of the components.

Mounting the ComExflex lamp module:

- Make sure the ComEx^{flex} lamp module to be fitted is intact (no cracks).
- Position the ComEx^{flex} lamp module's bayonet lock at the mounted lamp module actuator.
- Turn the locking bolt to connect the ComEx^{flex} lamp module securely to the lamp module actuator.



(i) Note

The assembly of the lamp module actuator as well as the assembly of the lamp module and the lamp module actuator is described in the operating instructions for actuating elements, type 05-0003-00../....

Installation

For fitting into enclosure

In hazardous areas groups I and II, the lamp module must be used:

- In appropriate enclosures with "Ex e" increased safety type of protection. The clearances and creepage distances under IEC/EN 60079-7 Section 4.3, Section 4.4 and Table 1 must be observed.
- In an enclosure that corresponds to another approved type of protection specified in IEC/EN 60079-0 Section 1.

With junction box


The ComEx^{flex} lamp module must be installed as a stationary unit and with protection against the risk of mechanical damage.

(i) Note

Avoid any capacitive influence from parallel conductors as well as any additional adverse heat effects on the cable.

Take care when connecting conductors:

- Strip 40 mm (1.6 in) sheath off the conductor.
- Remove approx. 6 mm (0.2 in) conductor insulation from the cores.
- Prepare the ends of fine-stranded and multi-stranded conductors: Crimp wire end sleeves with suitable crimping tools. Connection cross-sections: 0.75-2.5 mm² (14-18 AWG).
- Release terminals.
- Insert conductors diagonally.
- Tight the terminals with a maximum torque of 0.4-0.7 Nm (0.3-0.5 lb.ft), while holding the screwdriver slightly at an angle.



Terminal assignment:



ComExflex Lamp module Type 07-3353-41**/**

Commissioning

Before commissioning, check that:

- The ComExflex lamp module has been mounted and installed in compliance with regulations.
- The ComExflex lamp module is not damaged.
- The connection has been established properly (make sure the cores are secure).

Operation

▲ DANGER

Death or serious injury through improper

The ComExflex lamp module may be operated only within the technical limits that apply to it (see page 1).

Maintenance and Fault Clearance

⚠ WARNING

Risk of serious injury due to incorrect proceedings

- IEC/EN 60079-17 must be observed. It is recommended to formulate a maintenance plan according to this standard.
- Ensure that the voltage supply has been isolated or take suitable protective measures.

Maintenance

⚠ WARNING

Risk of serious accidents due to damaged

Check ComExflex lamp modules, lamp module actuators, screw fittings, sealings and cables regularly for cracks and damage. Make sure that they are properly established.

NOTICE

ComExflex lamp module/actuator damage due to incorrect cleaning.

It is not allowed to clean dirty ComExflex lamp modules/actuators with compressed

The operator of the ComExflex lamp module must keep it in good condition, operate it properly, monitor it and clean it regularly.

The owner/managing operator must schedule maintenance intervals which will suit the respective conditions of use.

Fault Clearance

⚠ WARNING

Risk of serious injury due to use of nonoriginal spare parts.

Use original parts only as replacements.

The ComExflex lamp module is defective if the LED cannot light up any more. Defective ComExflex lamp modules cannot be repaired: they must be replaced considering this operational instruction.

Defective lamp module actuators can be taken off and replaced by functioning lamp module actuators of the same type.

(i) Note

For original parts, contact the firm of Bartec GmbH at the service address.

Accessories, Spare Parts

The ComExflex lamp module can be connected to a junction box. Information on the junction box and junction box assembly is described in the Operating Instructions for the junction box, order number 05-0042-0050

For further accessories and spare parts, see BARTEC catalogue.

Disposal



Environmental damage can be caused by incorrect waste disposal. When in doubt, local authorities or specialist disposal companies can provide information on environmentally friendly


The components in the ComExflex lamp module and the lamp module actuator contain metal and plastic parts. Therefore the statutory requirements for disposing of electronic scrap must be observed


Service Address

BARTEC GmbH Max-Eyth-Straße 16 97980 Bad Mergentheim Germany

Tel.: +49 7931 597-0 +49 7931 597-119 Fax

Dimensions in mm (in)






Installation dimensions

NOTICE

Damage to elements due to incorrect installation dimensions.

The minimum spacing between the mounting holes must be observed.



Dimensions:

Dimonsions		
	mm	in
A *	75	2.95
В	16.5	0.7
С	Ø 30.3 ^{+0.3}	Ø 1.2 ^{+0.01}
D	3	0.1
E*	40	1.6

*Recommended spacing for mushroom pushbutton, slam button, and: position selector switches with protective shroud: 100 mm (3.9 in).



EU Konformitätsbescheinigung EU Attestation of Conformity Attestation UE de conformité **BARTEC**

№ 01-3300-7C0002 C

Wir	We	Nous
	BARTEC GmbH Max-Eyth-Straße 16 97980 Bad Mergentheim Germany	
erklären in alleiniger Verantwortung, dass das Produkt Leuchtmodul Leuchttaster	declare under our sole responsibility that the product Lamp module Illuminated button	attestons sous notre seule responsabilité que le produit Module de signalisation, Bouton-pousoir Iumineux

Typ 07-335*-***/****, 07-336*-***/****

auf das sich diese Erklärung bezieht den Anforderungen der folgenden Richtlinien (RL) entspricht

ATEX-Richtlinie 2014/34/EU RoHS-Richtlinie 2011/65/EU RoHS-Richtlinie 2015/863/EU

und mit folgenden Normen oder normativen Dokumenten übereinstimmt to which this declaration relates is in accordance with the provision of the following directives (D)

ATEX-Directive 2014/34/EU RoHS-Directive 2011/65/EU RoHS-Directive 2015/863/EU

and is in conformity with the following standards or other normative documents se référant à cette attestation correspond aux dispositions des directives (D) suivantes

Directive ATEX 2014/34/UE Directive RoHS 2011/65/UE Directive RoHS 2015/863/UE

et est conforme aux normes ou documents normatifs ci-dessous

EN 60079-0:2012 + A11:2013 EN 60079-1:2014 EN 60079-7:2015 EN 60079-11:2012 EN 60068-2-27:2009 EN 61000-6-2:2005 EN 61000-6-4:2007 + A1:2011

Verfahren der EU-Baumusterprüfung / Benannte Stelle Procedure of EU-Type Examination / Notified Body Procédure d'examen UE de type / Organisme Notifié

CML 17 ATEX 1106 U⁽¹⁾, Issue 2 2276, CML B.V., Hoogoorddreef 15, 1101BA Amsterdam, NL

⁽⁹⁾ Die Ex-Komponente ist Teil eines elektrischen Betriebsmittels oder eines Moduls, gekennzeichnet mit dem Symbol "U", das nicht für sich allein verwendet werden darf und über dessen Einbau in elektrische Betriebsmittel oder Systeme zur Verwendung in explosionsgefährdeten Bereichen gesondert entschieden werden muss.

Merkmale dieser Komponente sowie die Bedingungen für ihren Einbau in Geräte und Schutzsysteme siehe Betriebsanleitung der Komponente. ⁽⁷⁾The Ex-component is a part of an electrical apparatus or a module, marked with the symbol 'U', which is not intended to be used alone and requires additional consideration when incorporated into electrical apparatus or systems for use in explosive atmospheres.

Characteristics and how the component must be incorporated into equipment or protective systems see operation manual of the component. (9) Le composant Ex est partie de matériel électrique ou de module, marquée du symbol « U », ne devant pas être utilisée seule et nécessitant une certification complémentaire lorsqu'elle est incorporée a un matériel électrique ou à un système pour atmosphères explosives.

Les caractéristiques du composant ainsi que les conditions d'incorporation dans des appareils ou des systèmes de protection regarde voir l'instruction d'emploi du composant.

0044

Bad Mergentheim, 23.08.2019

i.A. Simon Dyhringer

Product Manager Ex e

i.V. Cristian Olareanu

Team Leader Certification Center

FB-0171d

Seite / page / page 1 von / of / de 1