



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX CML 14.0029X** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 9 Issue 8 (2019-08-05)
Date of Issue: 2021-10-27 Issue 7 (2018-03-13)
Applicant: **BARTEC GmbH** Issue 6 (2018-01-25)
Max-Eyth-Strasse 16 Issue 5 (2017-08-29)
97980 Bad Mergentheim Issue 4 (2017-03-09)
Germany Issue 3 (2016-12-12)
Issue 2 (2015-08-06)
Issue 1 (2015-02-09)
Issue 0 (2014-10-08)
Equipment: **ComEx Control and Indicating Stations, Type 07-351*-**

Optional accessory:
Type of Protection: **Flameproof "db", Increased Safety "eb", Intrinsic Safety "ib", Dust Ignition "tb"**
Marking: Ex db eb IIC T6 Gb or Ex db eb ia IIC T6 Gb
Ex tb IIIC T80°C Db
-55°C ≤ Ta ≤ +60°C

Approved for issue on behalf of the IECEx
Certification Body:

A Snowdon MIET

Position:

Assistant Certification Manager

Signature:
(for printed version)

A Snowdon

Date:

2021-10-27

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

Eurofins E&E CML Limited
Unit 1, Newport Business Park
New Port Road
Ellesmere Port, CH65 4LZ
United Kingdom





IECEX Certificate of Conformity

Certificate No.: **IECEX CML 14.0029X**

Page 2 of 4

Date of issue: 2021-10-27

Issue No: 9

Manufacturer: **BARTEC GmbH**
Max-Eyth-Strasse 16
97980 Bad Mergentheim
Germany

Additional
manufacturing
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

IEC 60079-1:2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
Edition:6.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"
Edition:2

IEC 60079-7:2017 Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[GB/CML/ExTR14.0016/00](#)
[GB/CML/ExTR16.0177/00](#)
[GB/CML/ExTR17.0177/00](#)
[GB/CML/ExTR21.0252/00](#)

[GB/CML/ExTR15.0008/00](#)
[GB/CML/ExTR17.0033/00](#)
[GB/CML/ExTR18.0068/00](#)

[GB/CML/ExTR15.0057/00](#)
[GB/CML/ExTR17.0161/00](#)
[GB/CML/ExTR19.0131/00](#)

Quality Assessment Report:

[DE/TUN/QAR06.0017/13](#)



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 14.0029X**

Page 3 of 4

Date of issue: 2021-10-27

Issue No: 9

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The ComEx are either single, double or triple control and/or indicating display stations.

The three standard thermoplastic enclosures, single (07-3511-* and 07-3514-*), double (07-3512-* and 07-3515-*) and triple (07-3513-* and 07-3516-*) can be combined with various separately certified actuators, switch modules and luminous modules.

The control and display stations may be optionally provided with cable glands and blanking elements, as well as an earthing plate.

Refer to Annex for full description and conditions of manufacture.

SPECIFIC CONDITIONS OF USE: YES as shown below:

Refer to Annex for Specific Conditions of Use.



IECEX Certificate of Conformity

Certificate No.: **IECEX CML 14.0029X**

Page 4 of 4

Date of issue: 2021-10-27

Issue No: 9

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Issue 1

This issue introduced the following change:

- i. To allow an alternative sealing material to be used

Issue 2

This issue introduced the following change:

- i. To correct a typographic error and clarify the approval standards

Issue 3

This issue introduced the following changes:

- i. To update certification drawings to reflect changes in enclosure manufacturing.
- ii. To update certificate to the latest standard editions.

Issue 4

This issue introduced the following change:

- i. To update drawings and manufacturing details for the locking device.

Issue 5

This issue introduced the following changes:

- i. The introduction of an alternative enclosure profile.
- ii. Clarification of the cable gland size options in the series type reference table on the certificate.

Issue 6

This issue introduced the following changes:

- i. The introduction of an alternative non-metallic sealing material between enclosures.
- ii. The introduction of an alternative metallic plug between enclosures.

Issue 7

This issue introduced the following change:

- i. The introduction of an alternative non-metallic sealing material between enclosures.

Issue 8

This issue introduced the following change:

- i. To update the certificate to include the 4-pole switch module covered under certificate number IECEx CML 17.0045U.

Issue 9

This issue introduced the following changes:

- i. Update of IEC 60079-0 to the latest Edition.
- ii. Update of IEC 60079-7 to the latest Edition.
- iii. Update to equipment designation.

Annex:

[IECEX CML 14.0029X Iss 9 Certificate Annex.pdf](#)

Annexe to: IECEx CML 14.0029X, Issue 9
Applicant: BARTEC GmbH
Apparatus: ComEx Control and Indicating Stations, Type 07-351*-*****

Description

The ComEx are either single, double or triple control and/or indicating display stations.

The three standard thermoplastic enclosures, single (07-3511-* and 07-3514-*), double (07-3512-* and 07-3515-*) and triple (07-3513-* and 07-3516-*) can be combined with various separately certified actuators, switch modules and luminous modules.

The control and display stations may be optionally provided with cable glands and blanking elements, as well as an earthing plate.

Ratings:

Increased safety and Dust types			
Type	07-3511-	07-3512-	07-3513-
Rated insulation voltage	690 V	690 V	690 V
Rated voltage, Max.	400 V	400 V	400 V
Rated current, Max.	Note: Allowable maximum voltages, currents and ambient may be higher or lower dependant on enclosure size and components fitted, see instructions for specific details		
At Ta 40°C	16 A	16 A	Up to 20 A
At Ta 60°C	11 A	11 A	Up to 14 A

Eurofins E&E CML Limited
 Newport Business Park
 New Port Road
 Ellesmere Port
 CH65 4LZ

T +44 (0) 151 559 1160
 E info@cmllex.com

www.cmllex.com

Company Reg No. 8554022 VAT No. GB163023642



Intrinsic safety types			
Type	07-3514-	07-3515-	07-3516-
Ui	30 V	30 V	30 V
Ii	150 mA	150 mA	150 mA
Pi	1 W	1 W	1 W
The Ci and Li values are negligible and therefore stated as zero			

Series model type reference:

07	-	3	5	1	*	-	*	*	*	*	*	*	*	*	*	*	*	*
A	-	B	C	D	E	-	F	G	H	I	J	K	L	M	N	O	P	

Type reference Prefix	Code for	Variation Prefix	Description
A	Basic designation	07	Common code number
B, C	Product sector	35	Code combination "e"
D	Enclosure material	1	Plastic material
E	Enclosure size	1	88 mm
		2	130 mm
		3	176 mm
		4	88 mm – Ex i
		5	130 mm – Ex i
		6	176 mm – Ex i
F	Cable gland, top of enclosure (Side B)	0	Without
		1	One, M20, plastic
		2	One, M25, plastic
		3	Two, M20, plastic
		4	One, M20, plastic one, M20, blanking element
		5	One, M20, metal
		6	One, M25, metal
		7	Two, M20, metal
		8	One, M20, metal one, M20, blanking element
		9	Special: 1 x ≤ M32 or 2 x ≤ M20 and 1 x ≤ M16 or 2 x ≤ M25 or 3 x ≤ M16
G	Cable gland, bottom of enclosure (Side A)	0	Without
		1	One, M20, plastic
		2	One, M25, plastic
		3	Two, M20, plastic

Type reference Prefix	Code for	Variation Prefix	Description
		4	One, M20, plastic one, M20, blanking element
		5	One, M20, metal
		6	One, M25, metal
		7	Two, M20, metal
		8	One, M20, metal one, M20, blanking element
		9	Special: 1 x ≤ M32 or 2 x ≤ M20 and 1 x ≤ M16 or 2 x ≤ M25 or 3 x ≤ M16
H - P	Applications	Variants with separately certified operators and modules	
	H - J	For use with all enclosure type/sizes	
	K - M	For use with: 07-3512, 07-3513, 07-3515 and 07-3516 type/sizes only	
	N - P	For use with: 07-3513 and 07-3516 type/sizes only	
H, I K, L N, O	Operators	00	Without operator
		B1	Blanking plug (05-0003-0019/****)
		D*	Potentiometer (05-0003-0076/****)
		E*	Lock types (05-0003-0077/**** to 05-0003-0080/****)
		H*	Position Selector Types (05-0003-0020/**** to 05-0003-0021/****)
		K*	Lock type (05-0003-0012/****)
		L*	Lamp module types (05-0003-0013/**** to 05-0003-0017/****)
		N*	Emergency button type (05-0003-0008/****)
		P*	Push button types (05-0003-0007/****, 05-0003-0018/****, 05-0003-0075/**** and 05-0003-0082/****)
		S*	Position Selector types (05-0003-0009/****, 05-0003-0011/****, 05-0003-0071/**** and 05-0003-0073/****)
		T*	Laminated Push Button types (05-0003-0065/**** to 05-0003-0069/****)
J, M, P	Modules	1	Switchmodule 2 NC
		2	Switchmodule 2 NO
		4	Switchmodule 1 NC / 1NO or Control switching unit 1 kΩ (dependant on operator type)
		5	Control switching unit 2,2 kΩ
		6	Control switching unit 4.7 kΩ or Terminal block
		7	Control switching unit 10 kΩ
		R	Lampmodule red
		Y	Lampmodule yellow

Type reference Prefix	Code for	Variation Prefix	Description
		W B A	Lampmodule white Lampmodule blue or Illuminated push button module 1 NO (depends on operator type) Illuminated push button module 1 NC
Or K – M N - P	Measuring Devices	MM*	Measuring device separately certified with different max. current
Or H - J	Operator (Control Switch)	G**	Position Selector type (05-0003-0062/****)
+ K - M	Control switch module	A** B** C** etc	Control switch module
Or H, I (K, L)	Operators	See above	
+ K – M (N - P)	Switch module, 4-pole	PV**	Switch Module, 4-pole
* Counting number without influence on the model reference code			

Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate. A copy of the certification for the components fitted shall be provided to the end user.
- ii. When limited components are provided for applications other than the Ex db eb ia IIC T6 Gb versions, the user shall be provided with the appropriate limitation information for these components.

Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. When equipment is marked 'Ex db eb ia' the circuits are separate intrinsically safe circuits and shall be used with appropriate barriers certified for 'Ex ia IIC' outputs.

Components covered by Ex Certificates issued to older editions of Standards

Certificate number	Standards (incl Ed)	Assessment result
IECEX CML 14.0005U	IEC 60079-0:2017 Ed. 7 IEC 60079-7:2017 Ed. 5.1 IEC 60079-31:2013 Ed. 2	No applicable technical differences. The component is assessed to the latest editions of the standard.
IECEX PTB 07.0046U	IEC 60079-0:2011 Ed. 6 IEC 60079-1:2014-06 Ed. 7 IEC 60079-7:2006-07 Ed. 4	Technical differences evaluated and found satisfactory. For detail see ExTR GB/CML/ExTR21.0252/00
IECEX PTB 10.0014U	IEC 60079-0:2011 Ed. 6 IEC 60079-1:2014-06 Ed. 7 IEC 60079-11:2011 Ed. 6 IEC 60079-7:2006-07 Ed. 4	Technical differences evaluated and found satisfactory. For detail see ExTR GB/CML/ExTR21.0252/00
IECEX PTB 04.0003U	IEC 60079-0:2017 Ed. 7 IEC 60079-7:2017 Ed. 5.1	No applicable technical differences. The component is assessed to the latest editions of the standard.
IECEX PTB 10.0017U	IEC 60079-0:2011 Ed. 6 IEC 60079-1:2014-06 Ed. 7 IEC 60079-7:2006-07 Ed. 4	Technical differences evaluated and found satisfactory. For detail see ExTR GB/CML/ExTR21.0252/00
IECEX CML 17.0045U	IEC 60079-0:2017 Ed. 7 IEC 60079-1:2014-06 Ed. 7 IEC 60079-7:2017 Ed. 5.1	No applicable technical differences. The component is assessed to the latest editions of the standard.