Certificate Number E486512

**Report Reference** E486512-20190426

Date 2021-November-18

Issued to: BARTEC F.N. S.R.L.

Via Mario Pagano 3

Trezzano S/Naviglio MI 20090 IT

This is to certify that representative samples of

INDUSTRIAL CONTROL PANELS AND ASSEMBLIES FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1203 - EXPLOSION-PROOF AND DUST-IGNITION-

PROOF ELECTRICAL EQUIPMENT FOR USE IN

HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 30-M1986 - EXPLOSION-PROOF ENCLOSURES FOR USE IN CLASS I HAZARDOUS

LOCATIONS

UL 698A - INDUSTRIAL CONTROL PANELS RELATING

TO HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 157-92 - INTRINSICALLY SAFE AND

NON-INCENDIVE EQUIPMENT FOR USE IN

HAZARDOUS LOCATIONS

Additional Information: See the UL Online Certifications Directory at

https://ig.ulprospector.com for additional information


This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up

Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's

Follow-Up Services.

Look for the UL Certification Mark on the product.





Certificate Number E486512


**Report Reference** E486512-20190426


Date 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Industrial Control Panels for Use in Class I, Division 1, Groups B, C and D Hazardous Locations.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; and Class III Hazardous Locations.





UL LLC



Certificate Number E486512

Report Reference E486512-20190427

Date 2021-November-18

Issued to: BARTEC F.N. S.R.L.

Via Mario Pagano 3

Trezzano S/Naviglio MI 20090 IT

This is to certify that representative samples of

INDUSTRIAL CONTROL PANELS AND ASSEMBLIES

FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 121

UL 121201 & CSA C22.2 NO. 213 - NONINCENDIVE

ELECTRICAL EQUIPMENT FOR USE IN CLASS I AND II,

DIVISION 2, AND CLASS III, DIVISIONS 1 AND 2

HAZARDOUS (CLASSIFIED) LOCATIONS

UL 698A - INDUSTRIAL CONTROL PANELS RELATING

TO HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 157-92 - INTRINSICALLY SAFE AND

NON-INCENDIVE EQUIPMENT FOR USE IN

**HAZARDOUS LOCATIONS** 

**Additional Information:** 

See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





Certificate Number E486512


Report Reference E486512-20190427

Date 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Nonincendive Industrial Control Panels for Use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Certificate Number E486512

**Report Reference** E486512-20190428

Date 2021-November-18

Issued to: BARTEC F.N. S.R.L.

Via Mario Pagano 3

Trezzano S/Naviglio MI 20090 IT

This is to certify that representative samples of

INDUSTRIAL CONTROL PANELS AND ASSEMBLIES

FOR USE IN HAZARDOUS LOCATIONS

See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: NFPA 49

NFPA 496 - PURGED AND PRESSURIZED

**ENCLOSURES FOR ELECTRICAL EQUIPMENT** 

UL 698A - INDUSTRIAL CONTROL PANELS RELATING

TO HAZARDOUS (CLASSIFIED) LOCATIONS

CSA C22.2 NO. 157-92 - INTRINSICALLY SAFE AND

NON-INCENDIVE EQUIPMENT FOR USE IN

HAZARDOUS LOCATIONS

Additional Information:


See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.





Certificate Number E486512

**Report Reference** E486512-20190428

Date 2021-November-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Industrial Control Panels For Use In Class I, Division 1, Groups A, B, C and D Hazardous Locations, Type X Purged and Pressurized.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III Hazardous Locations.

Industrial Control Panels For Use In Class I, Division 1, Groups A, B, C and D Hazardous Locations, Type Y Purged and Pressurized.

May be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III Hazardous Locations.

Industrial Control Panels For Use In Class I, Division 2, Groups A, B, C and D Hazardous Locations, Type Z Purged and Pressurized.

Type X, Type Y and Type Z Purged and Pressurized panels may be provided with intrinsically safe circuit extensions for use in Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F, G; and Class III Hazardous Locations.



