



IECEX Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEX BVS 13.0048X** Page 1 of 4 Certificate history:
Status: **Current** Issue No: 3 [Issue 2 \(2020-05-12\)](#)
Date of Issue: 2025-08-20 [Issue 1 \(2018-05-07\)](#)
Applicant: **BARTEC GmbH** [Issue 0 \(2013-08-01\)](#)
Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany
Equipment: **Heating system PLEXO TCS type 27-1100-****/******
Optional accessory:
Type of Protection: **General and testing requirements, Protection by Enclosure "t", Increased Safety "e"**
Marking: Ex eb 60079-30-1 IIC T6 ... T3 Gb
Ex tb 60079-30-1 IIIC T80°C ... T200°C Db

Approved for issue on behalf of the IECEx
Certification Body:

Dr Michael Wittler

Position:

Deputy Head of Certification Body

Signature:
(for printed version)

Date:
(for printed version)

2025-08-20

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

DEKRA Testing and Certification GmbH
Certification Body
Dinnendahlstrasse 9
44809 Bochum
Germany





IECEx Certificate of Conformity

Certificate No.: **IECEx BVS 13.0048X**

Page 2 of 4

Date of issue: 2025-08-20

Issue No: 3

Manufacturer: **BARTEC GmbH**
Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany

Manufacturing
locations: **BARTEC GmbH**
Max-Eyth-Straße 16
97980 Bad Mergentheim
Germany

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

[IEC 60079-0:2017](#) Explosive atmospheres - Part 0: Equipment - General requirements
Edition:7.0

[IEC 60079-31:2022](#) Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosure "t"
Edition:3.0

[IEC 60079-7:2017](#) Explosive atmospheres - Part 7: Equipment protection by increased safety "e"
Edition:5.1

[IEC/IEEE 60079-30-1:2015](#) Explosive atmospheres - Part 30-1: Electrical resistance trace heating - General and testing requirements
Edition:1.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/BVS/ExTR13.0091/03](#)

Quality Assessment Report:

[DE/TUN/QAR06.0017/15](#)



IECEx Certificate of Conformity

Certificate No.: **IECEx BVS 13.0048X**

Page 3 of 4

Date of issue: 2025-08-20

Issue No: 3

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Description

The heating system PLEXO TCS Type 27-1100-****/**** serves as a stationary heating device and consists of separately certified heating cable series (type PSB, MSB, HSB or HSB+) in conjunction with the PLEXO Tape Connector type 27-59P*-****/****.

The PLEXO Tape Connector type 27-59P*-****/**** can be used in following different versions:

- – Connection supply cable and heating cable (type 27-59P1-****/****)
- – Connection of heating cables (type 27-59P2-****/****)
- – End termination of heating cables (type 27-59P3-****/****)

The complete heating system is based on the type of protection Increased Safety "eb" and Protected by Enclosure "tb". Furthermore, the heating system meets the requirements of IEC 60079-30-1 Electrical resistance trace heating.

Subject and Type

See Annex

Parameters

See Annex

SPECIFIC CONDITIONS OF USE: YES as shown below:

- The classification of the temperature class of the PLEXO TCS Heating System is done from the operator depending on the used heating cable. The ambient temperature range of PLEXO TCS Heating System depends also of the used heating cable. This information is recorded on the operator side in accordance with the specifications in the operating instructions / acceptance report. The documentation must be kept secure.
- When used in TT and TN systems a residual current device according to IEC 60079-30-1, clause 4.4 point c1) shall be installed.

When used in IT systems an insulation monitoring device according to IEC 60079-30-1, clause 4.4 point c2) shall be used.



IECEX Certificate of Conformity

Certificate No.: **IECEX BVS 13.0048X**

Page 4 of 4

Date of issue: 2025-08-20

Issue No: 3

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

- Increase of max rated voltage of PLEXO TCS heating system to 277 V
- Including of HSB+ (up to 60 W/m) trace heaters in PLEXO TCS heating system
- Potential modification of PSB dimensions
- Modification of MSB dimensions
- Reintroduction of HSB cables
- Name of material for grommets changed
- Update of the standard IEC 60079-31

Annex:

[BVS_13_0048X_Bartec_Annex_issue3.pdf](#)



Certificate No.: IECEx BVS 13.0048X issue No.: 3
Annex
Page 1 of 2

Subject and Type

Heating system PLEXO TCS type 27-1100-*1)*2)*3)*/***

- 1) Rated voltage
 - 0: 110 V up to 120 V
 - 1: 208 V up to 277 V
- 2) Heating Cable series
 - 1: PSB Heating Cable series, type 07-5853-****
 - 2: MSB Heating Cable series, type 07-5854-****
 - 3: HSB Heating Cable series, type 07-5855-****
 - 4: HSB+ Heating Cable series, type 07-584B-****

- 3) Connection system
 - 5: PLEXO Tape Connector, with following variations

<u>Function</u>	<u>Type</u>	<u>Sealing range</u>
PLEXO Heating Cable connection	27-59P1-101*/****	9 ≤ D ≤ 10 mm
	27-59P1-201*/****	10 ≤ D ≤ 12 mm
	27-59P1-301*/****	12 ≤ D ≤ 14 mm
	27-59P1-401*/****	14 ≤ D ≤ 16 mm
PLEXO Heating Cable splice	27-59P2-011*/****	Heating Cables (see ²⁾)
PLEXO Heating Cable end termination	27-59P3-001*/****	Heating Cables (see ²⁾)



Certificate No.: **IECEX BVS 13.0048X** issue No.: **3**
Annex
 Page 2 of 2

Parameters

Type	Heating system PLEXO TCS Type 27-1100-*1**/**** (with PSB Heating cable)		Heating system PLEXO TCS Type 27-1100-*2**/**** (with MSB Heating cable)		Heating system PLEXO TCS Type 27-1100-*3**/**** (with HSB Heating cable)		Heating system PLEXO TCS Type 27-1100-*4**/**** (with HSB+ Heating cable)	
Rated voltage	Max. 277 V							
Rated power output [W/m]	≤15	≤33	≤15	≤60	≤15	≤60	≤30	≤60
Temperature class	T6	T5	T4	T3	T4	T3	T3	
min. ambient temperature [°C]	-55		-60				-40	
max. ambient temperature [°C]	+65		+110		+120		+150	+120
min. temperature stability supply cable [°C]	+75	+85	+120	+130	+120	+130	+160	+140
Max. fuse (type C)	32 A							
IP protection	IP65							
Rated connecting capacity range	0.5 mm ² – 4 mm ²							
Sealing range supply cable	9 ≤ D ≤ 16 mm							

Type	PLEXO Tape Connector Type 27-59P*-*****/****
Rated voltage	320 V (for insulation)
Withstand temperature range	-60 °C ≤ T ≤ +160 °C
IP protection	IP65
Rated connecting capacity range	0.5 mm ² – 4 mm ²
Sealing range supply cable	9 ≤ D ≤ 16 mm